

<div><p>CITY OF CAPE CORAL UTILITIES DEPARTMENT</p></div>	QUALIFIED PRODUCTS LISTING
	PLUG VALVES FOR LIFT STATIONS
	SPECIFICATION NUMBER
	15207. 2.1.D.
<p>MINIMUM REQUIREMENTS:</p> <p>15207. 2.1.D.</p> <p>All valves 6-inch and larger shall be equipped with gear actuators. The actuator must be the same manufacturer or brand of the installed valve.</p> <p>Valve bodies shall be of ASTMA536, 65-45-12 ductile iron</p> <p>All exposed nuts, bolts, springs, washers, etc. shall be 316 stainless steel and American made. Resilient plug facings shall be of Hycar or Neoprene.</p>	
	PRODUCTS
	DEZURIK (PEC SB16, F1 (Flanged) or MJ)
	NO SUBSTITUTIONS
	THE USER IS SOLELY REPOSNSIBLE FOR ASSURING THAT HE/SHE USES THE MOST RECENT REVISION
	Revision Date: 1/19/2016
	Attachment List
	<div>Name</div>
	No records to display.