



<div><p>CITY OF CAPE CORAL UTILITIES DEPARTMENT</p></div>	QUALIFIED PRODUCTS LISTING
	HYDRANT FLUSHING UNITS
	SPECIFICATION NUMBER
	15235. 2.3.B.
<p>MINIMUM REQUIREMENTS:</p> <p>15235. 2.3.B.</p> <p>The automatic flushing system shall be constructed of durable, powder-coated heavy gauge aluminum construction for long life and reliability. Unit shall be of a self-supporting, free standing design that limits stress on both the hydrant and flushing device. The flushing system shall include a sampling valve.</p> <p>Unit shall be adjustable for hydrant connections between 15.5” to 21” in order to accommodate various types of hydrants. Connection shall be 2-1/2” NST brass or as specified. Unit shall be operated by a 9-event battery powered programmer (powered by two Alkaline AA batteries. Unit shall have an integrated splash plate for erosion control.</p>	
PRODUCTS	
MUELLER (HYDROGUARD)	
OR CITY APPROVED EQUAL	
THE USER IS SOLELY REPOSNSIBLE FOR ASSURING THAT HE/SHE USES THE MOST RECENT REVISION	
Revision Date: 1/19/2016	
Attachment List	
Name	
No records to display.	