



CITY OF CAPE CORAL
UTILITIES DEPARTMENT

QUALIFIED PRODUCTS LISTING

STORM DRAIN PIPE PVC

SPECIFICATION NUMBER

02590.2.2.C

MINIMUM REQUIREMENTS:

02590. 2.2.C.

- A. All corrugated polyvinyl chloride pipe shall conform to Florida Department of Transportation Standard Specifications for Road and Bridge, Section 948.1.7. Corrugated PVC pipe for storm drain shall conform to ASTM F949 and ASTM 794 manufacturing and testing requirements. Pipe shall also conform to the minimum cell classification 12454 as specified in ASTM D 1784.
- B. Pipe and fittings shall be joined by the use of integral bell joints with a gasket compressed between the spigot and belled ends of the pipe. Elastomeric gaskets shall comply with the requirements of ASTM F 477. All joints and fittings shall be water tight.
- C. Manufacturer's, or City approved equal



PRODUCTS

CONTECH CONSTRUCTION
PRODUCTS (A-2000)

OR CITY APPROVED EQUAL

THE USER IS SOLELY RESPONSIBLE FOR ASSURING
THAT HE OR SHE USES THE MOST RECENT REVISION

REVISION DATE
1/5/2016